

# CLASS 00 RUBBER GLOVES **OEL**<sup>TM</sup>

## OEL RUBBER GLOVE CLASSES

| CLASS | TEST AC VOLT | AC VOLT USE | DC VOLT USE | LABEL COLOR |
|-------|--------------|-------------|-------------|-------------|
| 00    | 2,500        | 500         | 750         | BEIGE       |
| 0     | 5,000        | 1,000       | 1,500       | RED         |
| 1     | 10,000       | 7,500       | 11,250      | WHITE       |
| 2     | 20,000       | 17,000      | 25,500      | YELLOW      |
| 3     | 30,000       | 26,500      | 39,750      | GREEN       |
| 4     | 40,000       | 36,000      | 54,000      | ORANGE      |



## ORDERING INFORMATION

Part #: **IRG0011[COLOR][SIZE]**

Class: **00** (500V AC/750V DC)

Sizes: **8, 9, 10, 11, 12**

Available Color: **[B]** Black & **[R]** Red

Length: 11 Inches

## PRODUCT OVERVIEW

OEL Class 00 (500V AC/750V DC) 11" low voltage industrial rubber insulating gloves provide the best in class electrical protection. The Class 00 11" glove offers a comfortable design in an ergonomically friendly hand-at-a-natural-rest shapeless hand fatigue from non-splayed fingers and generously flared cuff allows room for clothing and improves ventilation. The OEL Class 00 Rubber Insulating gloves case-hardened finish provides a smoother surface for easy donning and doffing.

## Inspection

Once the electrical safety gloves have been issued, OSHA requires that "protective equipment be maintained in a safe, reliable condition." This requires that the gloves be inspected for any damage before each day's use. Gloves must also be inspected immediately following any incident that may have caused damage. OSHA also requires that insulating gloves be given an air test along with the inspection.

The air testing method is described in ASTM F496-14a Standard Specification for In-Service Care of Insulating Gloves and Sleeves.

## Storage

To help ensure the integrity of the gloves and worker safety, gloves need to be stored properly when not in use. Proper storage means that gloves must not be folded and need to be kept out of excessive heat, sunlight, humidity, ozone and any chemical or substance that could damage the rubber.

OEL Worldwide Industries Industrial branded gloves are manufactured to meet or exceed the requirements of the current version of ASTM D120, the standard specification for Industrial Rubber Insulating Gloves.

## Sizing Information

Sizing information and instructions for OEL Rubber Gloves is available at [www.oelsales.com/sizing](http://www.oelsales.com/sizing)

**OEL WORLDWIDE INDUSTRIES**

**OELSALES.COM**

**800.818.2244**

OEL Worldwide Industries is a premier manufacturer of Arc Flash Safety Apparel [NFPA 70E, ASTM 1506, ASTM F2178, CSA Z462 and OSHA 1910.269] and Insulated Hand Tools [1000V AC/1500V DC] [ASTM F1505, IEC 60900].

DISCLAIMER: All necessary company safety practices for use of rubber products should be followed and assigned per company/corporation safety policy/program.

OEL Worldwide Industries does not assume liability for the improper care and/or use of rubber products. Visual inspections and routine testing should be performed per necessary standards